



DEKALB COUNTY FIRE & RESCUE DEPARTMENT

Fire Marshal Division Jerry E. Wainright, Acting Assistant Fire Marshal

330 West Ponce de Leon Avenue Decatur, Georgia 30030

Phone: 404-371-2776 Fax: 404-687-2430

Fire Inspections: 404-371-3010 Chamblee/Doraville Fire Inspections: 404-371-2611

Project Name:	Architect/Engineer Contact Information:
Physical Address:	
Project No.:	Tommie G. Dunson, Jr.
Date Received:	Fire Protection Engineer
Date Reviewed:	Phone: (404) 371-6209

Plan Disapproved/Please Resubmit

Plan Approved/ Please Comply with Comments

**UNDERGROUND FIRELINE REVIEW ONLY-NOT A DOMESTIC
REVIEW**
**PLANS CANNOT BE SUBMITTED WITH A SPRINKLER PERMIT
APPLICATION**

Fireline plans must be submitted to the Land Development Office for all underground installations. Their office phone number is (404) 371-2365.

NOTICE

Fire Service Water Mains require each of the following:

- Plan submitted under separate permit and DEKALB Co. FMO approval of same prior to the installation of such mains per 2006 IFC section 501.3.
- Hydrostatic Testing and Flushing, per 2003 NFPA 20, *Fire Pumps* Sec. 11-1.1 & 11-1.2, and/or 2002 NFPA 24, *Private Fire Service Mains*, Sec. 10.10.2.2.
- Certification of Testing & Flushing, per NFPA 20: 11-1.3 & NFPA 24: Figure 10.10.1
- No pressure reducer shall be placed on any fire line per NFPA 24:5.3.
- No domestic service shall be provided from a fire line per NFPA 24: 1.1.1.

FIRE NOTES

1. Comply with NFPA 24, Standard For The Installation of Private Fire Service Mains and Their Appurtenances 2002 Edition.
2. Comply with of 2002 NFPA 24 section 4.1 Plans
3. Comply with 2002 NFPA 24 section 4.2.1: Installation work shall be done by fully experienced and responsible persons.
4. Comply with 2002 NFPA 24 Chapters 10 and 12 for underground and above ground piping.
5. Comply with 120-3-3, 2002 NFPA 24 section 13.1: No pipe smaller than a nominal 8 inches in diameter shall be used to supply hydrant and automatic extinguishing systems.

Revised: rsw: 7/20/10